


When using this configuration, S1-3 (Term) must be closed in the last unit on the chain, providing signal termination. All other units must have S1-3 open.



Engineer	BOM	Rev.	Assembly	Rev.
Approved	Fab.	Rev.	PCB	Rev.
 Two Vector FCUs with daisy-chained RS-485 communications				
Size	Number			Revision
Date:	11/27/2018			Sheet of
File:	J:\Employee's Folders\...\Two Vector FCUs with daisy-chained RS-485.SchDoc			